



EC type-examination certificate
EG-Baumusterprüfbescheinigung
Attestation d'examen CE de type

Certification No.: 08/208/AP 003/04

Notified Office: TÜV CERT Certification body of the
TÜV Hannover/Sachsen-Anhalt e.V.,
Ident. No.: 0032

Certificate owner: Henning GmbH
Loher Straße 30
D-58332 Schwelm

Date of application: 2000-09-14

Manufacturer: See Certificate owner

Product, type: Hydraulic lift buffer
LP 40 x 275

Test laboratory: Test laboratory for safety of technical systems

Date and number of test report: 00/PM20300 dated 2000-12-08

EU Directive: Lift directive 95/16/EC

Test result: The safety component satisfies the basic safety and health requirements of the Directive indicated for the field of application as specified in the annex on page 1 of this type-examination certificate.

Date of issue: 2000-12-08

TÜV CERT-Zertifizierungsstelle
für Maschinen, Aufzugs- und Fördertechnik
des TÜV Hannover/Sachsen-Anhalt e.V.

Head of the
Certification Body

A handwritten signature in black ink, appearing to be 'R. Rosin', written over a horizontal line.

(Rosin)



DAR-Reg.-No.: ZLS-ZE-136/97

Ident. No. of the notified body: 0032

Annexe to the EC type-examination certificate No. 08/208/APH 003/04, 1 page



Annex to the EC type-examination certificate No. 08/208/AP 003/04

1. Required information
 - 1.1 Hydraulic lift buffer LP 40 x 275
 - 1.2 Field of application: for use with lifts in accordance with directive 95/16/EC
 - 1.3 Maximum nominal speed: 2,0 m/s
 - 1.4 Maximum mass: 3000 kg
 - 1.5 Minimum mass: 450 kg
 - 1.6 For the selection of the types of oils and the dimensions see the operation manual of the manufacturer (version 1.6 dated 2000-08-22)

2. Note:

The EC type-examination certificate must be used together with the corresponding appendix only.

Hanover, 2000-12-08